

Push-button Type Photomicro Sensors

BS5-P Series
INSTRUCTION MANUAL

TCD25004AA

Autonics

Thank you for choosing our Autonics product.

Read and understand the instruction manual and manual thoroughly before using the product.

For your safety, read and follow the below safety considerations before using.

For your safety, read and follow the considerations written in the instruction manual, other manuals and Autonics website.

Keep this instruction manual in a place where you can find easily.

The specifications, dimensions, etc. are subject to change without notice for product improvement. Some models may be discontinued without notice.

Follow Autonics website for the latest information.

Safety Considerations

- Observe all ‘Safety Considerations’ for safe and proper operation to avoid hazards.
- ⚠ symbol indicates caution due to special circumstances in which hazards may occur.

⚠ Warning

Failure to follow instructions may result in serious injury or death.

01. Fail-safe device must be installed when using the unit with machinery that may cause serious injury or substantial economic loss. (e.g., nuclear power control, medical equipment, ships, vehicles, railways, aircraft, combustion apparatus, safety equipment, crime/disaster prevention devices, etc.)
Failure to follow this instruction may result in personal injury, economic loss or fire.
02. Do not use or store the unit in the place where flammable/explosive/ corrosive gas, high humidity, direct sunlight, radiant heat, vibration, impact or salinity may be present.
Failure to follow this instruction may result in explosion or fire.
03. Do not disassemble or modify the unit.
Failure to follow this instruction may result in fire.
04. Do not connect, repair, or inspect the unit while connected to a power source.
Failure to follow this instruction may result in fire.
05. Check ‘Connections’ before wiring.
Failure to follow this instruction may result in fire.

⚠ Caution

Failure to follow instructions may result in injury or product damage.

01. Use the unit within the rated specifications.
Failure to follow this instruction may result in fire or product damage.
02. Use a dry cloth to clean the unit, and do not use water or organic solvent.
Failure to follow this instruction may result in fire.

Cautions during Use

- Follow instructions in ‘Cautions during Use’. Otherwise, It may cause unexpected accidents.
- When connecting an inductive load such as DC relay or solenoid valve to the output, remove surge by using diodes or varistors.
- Use the product after 0.1 sec of the power input.
When using a separate power supply for the sensor and load, supply power to the sensor first.
- The power supply should be insulated and limited voltage/current or Class 2, SELV power supply device.
- Wire as short as possible and keep it away from high voltage lines or power lines to prevent surge and inductive noise.
- When using switching mode power supply (SMPS), ground F.G. terminal and connect a condenser between 0V and F.G. terminal to remove noise.
- When using a sensor with a noise-generating equipment (e.g., switching regulator, inverter, and servo motor), ground F.G. terminal of the equipment.
- This unit may be used in the following environments.
 - Indoors (in the environment condition rated in ‘Specifications’)
 - Altitude max. 2,000 m
 - Pollution degree 2
 - Installation category II

Ordering Information

This is only for reference, the actual product does not support all combinations. For selecting the specified model, follow the Autonics website.

BS	5	-	P	①	②	③	-	④	-	⑤
----	---	---	---	---	---	---	---	---	---	---

① Connection
1: Cable type (1 m)

② Size
M: Medium

③ Operation mode
L: Light ON (Unpressed button, output ON)
D: Dark ON (Pressed button, output ON)

④ Control output
No mark: NPN open collector output
P: PNP open collector output

⑤ Certification
No mark: CE, UKCA, EAC
U: CE, UKCA, UL Listed

Cautions during Installation

- Be sure to install this product by following the usage environment, location, and specified ratings. Consider the listed conditions below.
 - Installation environment
 - Button stop position, output switching position, and operation limit position
 - Operation load
- Use the M3 flat head screw to install, tighten with a torque of 0.59 N m or less.
- Do not impact with a hard object or bend the cable excessively. That could decrease the product’s water resistance.
- Do not pull the cable with a tensile strength of 30 N or over.
- Failure to follow this instruction may result in fire due to the open circuit.
- Use this product after the test. Check whether the indicator works appropriately for the positions of the detectable object.
- On the non-flush surface, install this product after inserting a spacer, as shown in [Fig. 1].

Recommended spacer
D: 6 mm
d: 3.3 mm
L: 4 ± 0.1 mm

Operation Timing Chart and Indicators		
Operation mode	Light ON	Dark ON
Button	Pressed	Pressed
	Unpressed	Unpressed
Received light	Received	Received
	Interrupted	Interrupted
Operation indicator (red)	ON	ON
	OFF	OFF
Transistor output	ON	ON
	OFF	OFF

Connections

NPN

PNP

Circuit

■ NPN open collector output

■ PNP open collector output

• OCP (over current protection), SCP (short circuit protection)

• If short-circuit the control output terminal or supply current over the rated specification, normal control signal is not output due to the protection circuit.

External Input Functions

You can connect the control wire (white) to an external device for the emitter OFF and check stable operation function

- Be sure to use a transistor that opens and closes 50 mA/10 V, and over 1/8 W resistors. Failure to follow this instruction may result in product damage.
- If the functions are not used, insulate the control wire (white).

■ Emitter OFF function

When the signal input occurs without pressing the button, you can check the receiver’s operation by stopping the emitter.

■ Check stable operation function

Without pressing the button, it reduces the LED intensity by about 20% and checks that the receiver is still receiving light (transistor ON). It helps to check in advance for malfunctions due to a decrease in the LED intensity.

■ Emitter OFF function+ Check stable operation function

Dimensions

- Unit: mm, For the detailed drawings, follow the Autonics website.

A

Operation indicator (red)

Specifications

Model	BS5-P1M□-□-□	BS5-P1M□-□-□- U
Sensing type	Push button type	
Button stop position ⁰¹⁾	5.0 ± 0.4 mm	
Button output switching position ⁰¹⁾	4.0 ± 0.5 mm	
Button operation limit position ⁰¹⁾	≤ 0 mm	
Operation load ⁰¹⁾	≤ 3 N	
Light source	Infrared LED	
Peak emission wavelength	940 nm	
Emitter OFF	YES (External input ⁰²⁾)	
Check stable operation	YES (External input ⁰²⁾)	
Operation mode	Light ON (Unpressed button, output ON) / Dark ON (Pressed button, output ON) mode model	
Indicator	Operation indicator (red)	
Certification	CE UKCA EAC	CE UKCA EAC
Unit weight (packaged)	≈ 30 g (≈ 50 g)	≈ 30 g (≈ 50 g)

01)

Operation load

Pressure required from stop position to output switching position

Stop position
Position of the button without any applied pressure

Operation limit position
Position of the button when fully pushed

Output switching position
Position where the output switches ON/OFF

02)

External input	NPN output	PNP output
Emitter OFF	Short at 0 V or ≤ 0.25 VDC≡ (outflow current ≤ 30 mA)	Short at +V or +V ≥ -0.25 VDC≡ (absorption current ≤ 30 mA)
Emitter ON	Open (leakage current ≤ 0.4 mA)	Open (leakage current ≤ 0.4 mA)
Response time	≤ 1 ms	

Power supply	12-24 VDC≡ ± 10 % (ripple P-P: ≤ 10 %)
Current consumption	≤ 35 mA
Control output	NPN open collector output / PNP open collector output model
Load voltage	≤ 26.4 VDC≡
Load current	≤ 50 mA
Residual voltage	NPN: ≤ 1.5 VDC≡, PNP: ≤ 1.5 VDC≡
Protection circuit	Reverse power protection circuit, output short overcurrent protection circuit
Insulation resistance	≥ 20 MΩ (250 VDC≡ megger)
Noise immunity	± 240 VDC≡ the square wave noise (pulse width: 1 μs) by the noise simulator
Dielectric strength	Between the charging part and the case : 1,000 VAC~ at 50/60 Hz for 1 min
Vibration	1.5 mm double amplitude at 10 to 55 Hz frequency in each X, Y, Z direction for 2 hours
Shock	500 m/s ² (≈ 50 G) in each X, Y, Z direction for 3 times
Mechanical life cycle	≥ 5,000,000 operations (1 operation = stop position - operation limit position - stop position)
Ambient illumination (receiver)	Fluorescent lamp: ≤ 1,000 lx
Ambient temperature	-20 to 55 °C, storage: -25 to 70 °C (no freezing or condensation)
Ambient humidity	35 to 85 %RH, storage: 35 to 85 %RH (no freezing or condensation)
Protection rating	IP40 (IEC standard)
Connection method	Cable type
Cable specification	Ø 3 mm, 4-wire, 1 m
Wire specification	Refer to the specifications below depending on the models.
BS5-P1M□-□-□	AWG26 (0.08 mm, 30-core), insulator outer diameter: Ø 0.93 mm
BS5-P1M□-□-□- U	AWG26 (0.08 mm, 28-core), insulator outer diameter: Ø 0.9 mm
Material	Case: PC + G, button: POM, sleeve: SUS304